

# Blount County Dept. of Building Safety

## 2006 IRC – DUCT INSTALLATION & INSULATION



Rev. 10202011

### 2006 International Residential Code ®

#### INSULATION

##### N1103.2 Ducts.

**N1103.2.1 Insulation (Based on 2009 IRC).** Supply and return ducts located in attic spaces shall be insulated to a minimum of R-8. All other ducts shall be insulated to a minimum of R-6. **Exception:** Ducts or portions thereof located completely inside the building thermal envelope.

**N1103.2.2 Sealing.** Ducts, air handlers, filter boxes and building cavities used as ducts shall be sealed. Joints and seams shall comply with Section M1601.3.1.

**N1103.2.3 Building cavities.** Building framing cavities shall not be used as supply ducts.

#### DEFINITIONS

**BUILDING THERMAL ENVELOPE.** The basement walls, exterior walls, floor, roof and any other building element that enclose conditioned spaces.

**CONDITIONED SPACE.** For energy purposes, space within a building that is provided with heating and/or cooling equipment or systems capable of maintaining, through design or heat loss/gain, 50°F (10°C) during the heating season and 85°F (29°C) during the cooling season, or communicates directly with a conditioned space. For mechanical purposes, an area, room or space being heated or cooled by any equipment or appliance.

#### GARAGE DUCT INSTALLATION

**R309.1.1 Duct penetration.** Ducts in the garage and ducts penetrating the walls or ceilings separating the dwelling from the garage shall be constructed of a minimum No. 26 gage (0.48 mm) sheet steel or other approved material and shall have no openings into the garage.

**R309.1.2 Other penetrations.** Penetrations through the separation required in Section R309.2 shall be protected by filling the opening around the penetrating item with approved material to resist the free passage of flame and products of combustion.